

**PRIMACOUSTIC STRATOTILE™**  
**Fiberglass Composite Acoustic Ceiling Tile**

TEST DATE: April 07, 2008  
 TEST REPORT: Light Reflectance for StratoTile Acoustic Ceiling Board Sample  
 SPECIMEN: Primacoustic StratoTile  
 RELEVANT STANDARD: ASTM E1477-98a

SAMPLE			LIGHT REFLECTANCE (LR)
Test I.D.	Client I.D.	Finish	
P210-2424-00	Stratotile	Absolute White Water based latex coating	0.84 0.84
			AVERAGE = 0.84
P200-2424-00	Thundertile	Absolute White Water based latex coating	0.84 0.84
			AVERAGE = 0.84

This test report is for reference only and should be read in conjunction with the original. It has been condensed and reformatted to provide quick reference. Specifying engineers and sales associates should consult the entire test before using or recommending this product. You may download this test in PDF format from the Primacoustic web site or via email by contacting the company. Note that accredited test facilities present their findings based on standard industry tests and suitability of the product will depend on installation, application and other factors which are to be determined by the user, sales associate or specifying engineer. Primacoustic, its associated companies, staff and directors make no claims beyond the full test report.